

Type Test Report

TÜV Rheinland®

Notification No.: 1008

Test Report No.:

28240339 001

Order No.: 93356030

Page 1 / 3

Client:

JIANGSU ZHONGTIAN TECHNOLOGY CO., LTD.

"1+" or "3"

No.1 Zhongtian Road, Hekou Town, Rudong County, 226463 Jiangsu Province, CHINA

Test item:

Optical Fiber Cable

Manufacturer and
manufacturing plant:

JIANGSU ZHONGTIAN TECHNOLOGY CO., LTD.

No.1 Zhongtian Road, Hekou Town, Rudong County, 226463 Jiangsu Province

Identification:

TEST OVERVIEW (TEST RESULTS)

Serial No.:

Harmonised standard: EN 50575:2014 + A1:2016

Classification standard: EN 13501-6:2014

Throughout this report a comma is used as the decimal separator

Abbreviations: ok / P = passed
fail / F = failed
n.a. / N/A = not applicable
data / D = publication of data

This test report relates to the a. m. test item. Without permission of the test center this test report is not permitted to be

Photo documentation**Before test****After test****Measuring equipment list**

Device	Manufacturer	Type	Identification No.	Next calibration
Measuring tape	Stabila	BM 30W	503509	2019.09.21.
Stop-watch	Helvetia	S001	502911	2017.10.25.
Digital caliper	Mitutoyo	CD-15B	0556014003	2018.01.03.
Digital temperature and	TESA	TESA 635	800000	2019.01.01.

-END OF TEST REPORT-